



TEST REPORT nr. S11116301

Safety (LVD)

Test item

Description.....: BUSWAY
 Trademark: POGLIANO BUSBAR
 Model/Type.....: 1. 235100S1LPA
 2. 234600S1LPA

Test Specification

Standard.....: EN 60529:1991 + A1:2000

Client's name: POGLIANO BUSBAR S.r.l.
 Address.....: C.rso Allamano, 43 - 10095 GRUGLIASCO (TO) - ITALY

Manufacturer's name : Same as client
 Address.....: --

Report

Tested by.....: M. Dal Santo - Technician

M. Dal Santo

Approved by.....: R. Beghetto - Laboratory Manager

R. Beghetto

Date of issue.....: 01.08.11

Contents: 18 pages



This test report shall not be reproduced except in full without the written approval of CMC.
 The test results presented in this report relate only to the item tested.

CMC Centro Misure Compatibilità S.r.l.



Index

1.	SUMMARY	3
2.	DESCRIPTION OF EQUIPMENT UNDER TEST (EUT)	4
3.	TESTING AND SAMPLING	4
4.	OPERATIVE CONDITIONS	4
5.	PHOTOGRAPH(S) OF EUT	5
5.1	PHOTOGRAPH(S) OF EUT.....	5
5.2	PHOTOGRAPH(S) OF SETUP.....	7
6.	EQUIPMENT LIST	9
7.	MEASUREMENT UNCERTAINTY	12
8.	REFERENCE DOCUMENTS	13
9.	DEVIATION FROM TEST SPECIFICATION	14
10.	TEST CASE VERDICTS	14
11.	RESULTS	14
11.1	IP CODE.....	15
11.2	IP CODE.....	17

CMC Centro Misure Compatibilità S.r.l.



1. Summary

Reference standard:

EN 60529:1991 + A1:2000

Clause	Test	Remark	Verdict
10.	Marking	IP65	P
11.	General requirements for the tests	--	P
12.	Protection against access to hazardous parts indicated by the first characteristic number	--	P
13.	Protection against solid foreign object indicated by the first characteristic number	--	P
14.	Tests for protection against water indicated by the second characteristic numeral	--	P

Remarks: Results are written following the exactly sequence of the performed measurement.



Mes

CMC Centro Misure Compatibilità S.r.l.



5. Photograph(s) of EUT

5.1 Photograph(s) of EUT



CMC Centro Misure Compatibilità S.r.l.

