



Gatteo 07/12/2012

Spett.le
Pogliano BusBar s.r.l.
Corso Allamano, 43
10095 GRUGLIASCO (TO)

Subject: Glow Wire Test

The glow wire test was performed according to par. 8.2.13 of the standard CEI EN 60439-2 2002 on the items shown in the pictures below.



The test was carried out at the LVD Test Laboratory in Istituto Giordano Spa.

The test specimens were exposed to 850 °C glow wire.

The result has been successful.

The Chief of LVD Department Lab

Ing. Gian Marco De Lucia



Sede centrale
Via Rossini, 2
47814 Bellaria (RN) Italy
Tel. +39 0541 343030
Fax +39 0541 345540
istitutogiordano@giordano.it
www.giordano.it

Distaccamento Bellaria
Via del Lavoro, 1/3
47814 Bellaria (RN) Italy
Tel. +39 0541 343030
Fax +39 0541 340659

Distaccamento Gatteo
Via Erbosa 1° tratto, 70/84/Via
Verga, 6
47043 Gatteo (FC) Italy
Tel. +39 0541 322300
Fax +39 0541 322385 (via Erbosa)
Fax +39 0541 818802 (via Verga)
sede.gatteo@giordano.it

Distaccamento Pomezia
Via Honduras, s.n.c.
00040 Pomezia (RM) Italy
Tel. +39 06 91602332
Fax +39 06 91602074
sede.pomezia@giordano.it