



TEST REPORT nr. S11116302

Safety (LVD)

Test item

Description.....: BUSWAY
 Trademark: POGLIANO BUSBAR
 Model/Type.....: 1. 235100S1LPA
 2. 234600S1LPA

Test Specification

Standard: EN 60529:1991 + A1:2000

Client's name: POGLIANO BUSBAR S.r.l.
 Address.....: C.rso Allamano, 43 - 10095 GRUGLIASCO (TO) - ITALY

Manufacturer's name : Same as client
 Address.....: --

Report

Tested by.....: M. Dal Santo - Technician

M. Dal Santo

Approved by.....: R. Beghetto - Laboratory Manager

R. Beghetto

Date of issue.....: 01.08.11

Contents: 18 pages



This test report shall not be reproduced except in full without the written approval of CMC.
 The test results presented in this report relate only to the item tested.



Index

1. SUMMARY	3
2. DESCRIPTION OF EQUIPMENT UNDER TEST (EUT)	4
3. TESTING AND SAMPLING	4
4. OPERATIVE CONDITIONS.....	4
5. PHOTOGRAPH(S) OF EUT	5
5.1 PHOTOGRAPH(S) OF EUT.....	5
5.2 PHOTOGRAPH(S) OF SETUP.....	7
6. EQUIPMENT LIST	9
7. MEASUREMENT UNCERTAINTY	12
8. REFERENCE DOCUMENTS.....	13
9. DEVIATION FROM TEST SPECIFICATION.....	14
10. TEST CASE VERDICTS	14
11. RESULTS	14
11.1 IP CODE.....	15
11.2 IP CODE.....	17

CMC Centro Misure Compatibilità S.r.l.



1. Summary

Reference standard:

EN 60529:1991 + A1:2000

Clause	Test	Remark	Verdict
10.	Marking	IP55	P
11.	General requirements for the tests	--	P
12.	Protection against access to hazardous parts indicated by the first characteristic number	--	P
13.	Protection against solid foreign object indicated by the first characteristic number	--	P
14.	Tests for protection against water indicated by the second characteristic numeral	--	P

Remarks: Results are written following the exactly sequence of the performed measurement.

Mols

CMC Centro Misure Compatibilità S.r.l.



2. Description of Equipment under test (EUT)

Rating(s): --
Serial Number.....: --
Components list.....: Annex 1
Degree of protection (IP code): IP55
Construction devices.....: --

3. Testing and sampling

Date of receipt of test item: 27.07.11
Testing start date.....: 27.07.11
Testing end date.....: 29.07.11
Samples tested nr.: 1 for model 235100S1LPA
1 for model 234600S1LPA
Sampling procedure.....: Equipment used for testing was picked up by
the manufacturer, at the end of the production
process with random criterion
Internal identification.....: adhesive label with the product number
P110797


4. Operative conditions


EUT exercising.....: --
Performance check for test: The enclosure shall be inspected for ingress of
water
No deposit of dust inside the enclosure
Auxiliary Equipment: None



5. Photograph(s) of EUT

5.1 Photograph(s) of EUT





Centro Misure Compatibilità S.r.l.

